

Christine Joyce

From: Robert Craig
Sent: Friday, August 21, 2009 1:33 PM
To: Christine Joyce
Subject: Comprehensive Permit- 99 Parker Street

Please be advised that I have reviewed the above named plan and would concur with comments already submitted by the Engineering Department specifically related to turning radii and the need for additional information regarding the open grate in the drive, specifically relative to support of fire apparatus.

Robert C. Craig, Fire Chief
Acton Fire Department
371 Main Street - Acton, MA 01720

Phone: (978) 264-9645 / Fax: (978) 266-2885
rcraig@acton-ma.gov